



Certificate of Approval

Certificate No.: SAA122059EA
Date of Issue: 8 October 2012

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

Certificate Holder: Unipro Industrial Electrical Importers NZ Ltd
55 St. John Street,
Tauranga, 3110
New Zealand

Class Description: Residual Current Device
Product Description: 1 Module Width RCBO with A and AC Type
B and C Curve

Brand Name: PRO SERIES
Model No.: CB10

Markings: $U_e=240V\sim(1P+N)$
 $I_n=6A, 10A, 16A, 20A, 25A$
Instantaneous tripping curve=B and C
 $I_{\Delta n}=30mA$, Type A and Type AC

Standard: AS/NZS 61009.1:2011
Conditions: Nil

Approval Mark: SAA122059EA or RCM


Date First Registered: 8 October 2012
Date of Expiry: 8 October 2017

Guina

For and on Behalf of
SAA Approvals Pty Ltd



JAS-ANZ



www.jas-anz.org/register

122059/1